

ADDENDUM NO. 1

PROJECT: **Lower Williams Street Repair
City of Deadwood, SD**

BID LETTING: May 3, 2010 at 5:00 P.M. MDT

LOCATION: CETEC Engineering Services, Inc.
1560 Concourse Drive
Rapid City, SD 57703

SCOPE: This Addendum consists of one page, A1.1.

ACKNOWLEDGMENT: Bidder shall acknowledge receipt of this Addendum in the Bidders Proposal form on page 00310.1.

DATE: Monday, April 26, 2010

CHANGES / CLARIFICATIONS / ADDITIONS TO PLANS AND SPECIFICATIONS:


<u>Item</u>	<u>Description</u>
-------------	--------------------

1.1	W-Beam Guardrail Post Installation.
-----	-------------------------------------

REMOVE the following requirements from the plans:

Sheet 10 of 10: Concrete anchoring of every other guardrail post will not be required. Disregard all notes and concrete anchoring details that refer to anchoring of every other guardrail post as shown within Sheet 10 of 10. All other aspects of the plans including post spacing and guardrail design are to remain the same. Note that existing guardrail is to be salvaged and reset with a new terminal end section and new posts per plan sheet 5 of 10.

CETEC Engineering Services, Inc.

By: 
Brian Tideman, P.E., Project Engineer

Date: 4-26-10