

**ADDENDUM NO. 1**

PROJECT: **Wall 2010 Street Improvements  
City of Wall, SD**

BID LETTING: June 10, 2010 at 2:00 P.M. MDT

LOCATION: CETEC Engineering Services, Inc.  
1560 Concourse Drive  
Rapid City, SD 57703

SCOPE: This Addendum consists of one page, A1.1.

ACKNOWLEDGMENT: Bidder shall acknowledge receipt of this Addendum in the Bidders Proposal form on page 00310.1.

DATE: Monday, June 7, 2010

CHANGES / CLARIFICATIONS / ADDITIONS TO PLANS AND SPECIFICATIONS:

**Item      Description**

1.1 00320.1 Bid Schedule & Plan Sheet 2 of 10 Quantity Table.


**REMOVE** the word "Tack" from Item No. 15 "Asphalt Tack for Geotextile Fabric" and replace with the word: "Cement".

1.2 02515.1 Sections 1.5.B; 2.3; 3.2; and 3.3.

**REMOVE** the word "Tack" in all instances and replace with the word: "Cement".

**Note** that Geotextile Asphalt Overlay Fabric is to be placed over a layer of Asphalt "Cement" placed at a rate of 0.3 gallons per square yard meeting the requirements listed on page 02515.2 under section 2.3. Refer to specification section 02515 for all Geotextile Asphalt Overlay Fabric construction requirements and associated materials.

CETEC Engineering Services, Inc.

By:   
Brian Tideman, P.E., Project Engineer

Date: 6-7-10